





Adres:

ul.Niepodległości 178/6 w Wałbrzychu

Wyniki doboru grzejników:

Pomieszczenie	Q	Dobraný grzejnik	L	H	G	Numer katalogowy
	W		[m]	[m]	[m]	
Pokój 1	1065	C22-50	0,90	0,50	0,10	
Pokój 2	690	C22-50	0,60	0,50	0,10	
Kuchnia	622	C22-50	0,50	0,50	0,10	
Łazienka+WC+Przedpok	680	C22-50	0,70	0,50	0,10	

Zestawienie materiałów:

Typ	Symbol	L	H	Numer katalogowy	Ilość	Producent
		[m]	m		[szt.]	
	C22-50	0,50	0,500		1	PURMO
	C22-50	0,60	0,500		1	PURMO
	C22-50	0,70	0,500		1	PURMO
	C22-50	0,90	0,500		1	PURMO